

NFRWQPA 2007 WATER QUALITY PLAN UPDATE
Industrial Point Source Inventory Data

Operating Agency: *Colorado Sweet Gold*

NPDES Permit #: COX-0001058

Permit Expires: 6/30/2010

Description of Treatment Facilities: Equalization tanks, sulfur dioxide reaction tank, pH modification tank, dissolved air flotation, clarification, and reuse or land application.

Treatment Facility Location: Section 9, T4N, R67W

Discharge Location: Section 9, T4N, R67W – land application

Stream Segment Classification:

Capacities:

	Design Capacity	Existing Load
Flow (mgd)	0.430	0.2
Organic (lbs/day BOD ₅)	1,750 (7 day ave.)	

Effluent limits required beyond secondary to meet stream standards: None

Estimated 5-year construction needs: None