

NFRWQPA 2011 WATER QUALITY PLAN UPDATE
Minor Point Source Inventory Data

Operating Agency: *Hemingway Lodge at Eagles Nest*

CDPS Permit #: COX-621050

Permit Expires: 4/30/2012

Description of Treatment Facilities: Lift stations, septic tanks, and soil absorption field.

Treatment Facility Location: Septic tanks: SE ¼, NW ¼, Section 18, T4N, R61W. Soil absorption field: NW ¼, NW ¼, Section 18, T4N, R61W.

Discharge Location: NW ¼, NW ¼, Section 18, T4N, R61W.

Stream Segment Classification: NA

Service Area Population: The lodge consists of a total of 16 bedrooms plus a three bedroom caretaker's house.

Capacities:

| | Design Capacity | Existing Load |
|-------------------------------------|-----------------|---------------|
| Flow (mgd) | 0.00495 | 0.0014 |
| Organic (lbs/day BOD ₅) | 12.5 | 1.97 |

Biosolids treatment and disposal: NA

Treatment level: The degree of treatment required and effluent limitations are outlined in Permit #COX-0046639.

Estimated 5-year construction needs: Not available.