

NFRWQPA 2011 WATER QUALITY PLAN UPDATE
Minor Point Source Inventory Data

Operating Agency: *Yogi Bear's Jellystone Park*

CDPS Permit #: COG-0630049

Permit Expired: 10/31/2015

CDPS Facility #: COG-0630049

Description of Treatment Facilities: Extended aeration activated sludge plant with polishing / infiltration pond (approximately 3,600 sq. ft. in area by 4 ft. deep), and chlorine contact equalization basin.

Treatment Facility Location: SW ¼, NW ¼, Section 2, T4N, R72W.

Discharge Location: To infiltration galleries in the Little Thompson River drainage, SW ¼, NW ¼, Section 2, T4N, R72W.

Stream Segment Classification: NA, discharge to groundwater.

Service Area Population: Existing average population approximately 400/week at peak summer capacity.

Capacities:

	Design Capacity	Existing Load
Flow (mgd)	0.010	0.006 (at peak summer usage)
Organic (lbs/day BOD ₅)	22.7	Not available

Treatment level: The degree of treatment required and effluent limitations are outlined in Permit #COG-0630049.

Estimated 5-year construction needs: None.