

NFRWQPA 2007 WATER QUALITY PLAN UPDATE  
Minor Point Source Inventory Data

Operating Agency: *Yogi Bear's Jellystone Park*

NPDES Permit #: COG-0630049

Permit Expired: 10/31/2015

NPDES Facility #: COG-0630049

Description of Treatment Facilities: Extended aeration activated sludge plant with polishing / infiltration pond (approximately 3,600 sq. ft. in area by 4 ft. deep).

Treatment Facility Location:

Discharge Location: To infiltration galleries in the Little Thompson River drainage, SW ¼, NW ¼, Section 2, T4N, R72W.

Stream Segment Classification: Cold Water Aquatic Life Class 1, Recreation Class 1a, Water Supply, and Agriculture.

Service Area Population: Existing average population approximately 400.

Capacities:

	Design Capacity	Existing Load
Flow (mgd)	0.010	0.006
Organic (lbs/day BOD <sub>5</sub> )	22.7	

Effluent limits required beyond secondary to meet stream standards: None